

## TOWN OF BRIDGEVILLE

**WWTP Monthly Report for OCTOBER 2020** 

Date: November 4, 2020

**Superintendents Report** 

- 1. All reports and testing are being completed
- 2. Check Valve replace on raw pump B
- 3. Replace motor on RBC A4
- 4. Installed new pressure switch on Rig #1
- 5. Installed Comminutor A motor has short in power line waiting on parts to fix

Respectfully Submitted,

Patrick J. Rankin

**Wastewater Superintendent** 

## TOWN OF BRIDGEVILLE WWTP MONTHLY REPORT OCTOBER 2020

**DATE: NOVEMBER 4, 2020** 

BRIDGEVILLE		GREENWOOD
908,000	<b>MAXIMUM</b>	271,244
374,900	<b>AVERAGE</b>	84,379
11,622,000	TOTAL	2,615,757

TOTAL COMBINED FLOW = 14,237,757

GREENWOOD'S PERCENTAGE OF FLOW = 22.51 %

## NPDES PERMIT REPORT

**TOTAL DAYS STREAM DISCHARGE = 0** 

AVERAGE DAILY STREAM FLOW = 0

TOTAL STREAM DISCHARGE = 0

## SPRAY IRRAGATION PERMIT REPORT

**TOTAL DAYS DISCHARGE TO LAGOON = 31** 

**AVERAGE DAILY FLOW TO LAGOON = 374,900** 

**TOTAL FLOW DISCHARGE TO LAGOON = 11,622,000** 

**TOTAL DAYS IRRAGATED = 16** 

**TOTAL GALLONS SPRAYED ON FIELD = 10,293,000** 

**TOAL SPRAY VIOLATIONS = 0**